



OTHER UNDERGROUND METER BASE MOUNTING OPTIONS

METER BASE SPECIFICATIONS :

- METER BASE SIZE TO BE COORDINATED WITH VEC FOR LOADING
- METER SOCKET MUST BE A PLUG IN TYPE METER, RING OR RINGLESS
- METER BASE MUST BE MOUNTED PER NATIONAL ELECTRIC CODE
- METER BASE DISCONNECT MAY BE MOUNTED AS AN ALL IN ONE OR WITH METER BASE AND DISCONNECT SEPARATED

ALL POLES TO BE 6X6 TREATED

ALL CLAMPS TO BE DETERMINED BY NATIONAL ELECTRIC CODES

ALL CUST. OWNED PIPE TO BE DETERMINED BY NATIONAL ELECTRIC CODES

FINAL GRADE

FINAL GRADE

24"

ALL PVC EXPOSED TO SUN TO BE SCH 80

CUSTOMER OWNED SERVICE ENTRANCE

SERVICE

3'-0"

SERVICE PVC SIZE
 400A PANEL / 3" SCH 40 GRAY PVC
 200A PANEL / 2-1/2" SCH 40 GRAY PVC
 ALL ELBOWS TO BE GRAY PVC 36" LONG SWEEP

POLE MUST BE CONCRETED IN PLACE FROM BOTTOM TO FINAL GRADE

NUMBER AND SIZE OF GROUND AND GROUND RODS TO BE DETERMINED BY NATIONAL ELECTRIC CODE

7'-0"

5'-6"

ALL SERVICE AND SECONDARY PIPES MUST HAVE A PULL STRING

METER BASE POLE INSTALLED BY CUSTOMER AND INSPECTED BY STATE INSPECTOR

NOT TO SCALE

SINGLE PHASE PERMANENT UNDERGROUND
 METER BASE ON A POLE

..VEEC logo_color_rgb.jpg

DRAWN BY: DLB

REVISED: 12/6/22