



**NOTES:**

1 - BOX MUST BE EQUIPPED WITH PROVISION FOR ADDITIONAL BRANCH CIRCUIT FEEDS FOR FUTURE USE.

Item No.	Material	Qty.
1	SERVICE POLE, 16'-0" LENGTH, 6" THICKNESS (or class 6 if round)	1
2	2" ALUMINUM CONDUIT CLAMP	As Req'd.
3	2" SCH. 80 PVC CONDUIT	2
4	1 $\emptyset$ , 200 A METER BASE, ANCHOR CAT. NO. URS1904-G-H0	1
5	60 A, 240 V, BREAKER CABINET	1
6	APPROVED ACORN GROUND ROD CLAMP	1
7	GROUND ROD, 5/8" X 8' COPPERWELD	1

BY: CKD

DATE: 11/15/01



1 $\emptyset$  TEMPORARY SERVICE  
METER POLE INSTALLATION

STANDARD  
DETAIL

SK-81